

Office of Facilities Management and Capital Planning Standard Temperature Settings

- Indoor temperature settings in all spaces while the building is open will be:
 - heated to a target temperature of 70 - 72° F during the winter
 - cooled to a target temperature of 74 - 76° F in centrally air conditioned spaces during the summer
- We recognize that temperatures will fluctuate within the building and every effort will be made to stay within plus/minus 2° F of the set point range
- Heating and cooling ranges will be set & monitored by Facilities Management in centrally controlled systems. Occupants who control their own thermostats are required to adhere to these settings
- Temperature set-backs are performed during unoccupied hours in an effort to conserve energy and to be a responsible ecological partner
- Supplemental electric heaters shall only be issued in the case of long-term system malfunctions and as authorized and provided by Facilities Management
- No other use of electric heaters is allowed and unauthorized heaters will be removed